


# COAXIAL SURGE PROTECTOR DEVICE, Quarter-wave stub technology with integrated high-pass filter

3407.17.0022

## Properties

- Residual voltage reduced by 80 % compared to standard types of series 3400
- Residual energy reduced of more than 99.9 % compared to series 3401 and 3402
- DC-blocking on protected side of the device
- Available for applications from 70 MHz to 18 GHz
- Return loss 20 dB min. and Insertion loss 0.2 dB max.



## Product configuration

Main path connectors	Port 1: unprotected, N jack (female) Port 2: protected, N jack (female)
Mounting and grounding	MH74 (bulkhead mounting), M8 (screw), brk (bracket)
Side of bulkhead	protected side

## Interface and material data

Housing material / plating	Brass / SUCOPLATE (R) Plating
Center contact, material / plating	Port 1: Copper Beryllium Alloy / Gold Plating (without Nickel underplating)
	Port 2: Copper Beryllium Alloy / Gold Plating (without Nickel underplating)

## Electrical data

Impedance	50 Ω
Frequency frame	74 MHz to 180 MHz
Return loss typical	20 dB
Insertion loss typical	0.15 dB
CW power frame	500 W

## Electrical remarks

Surge current handling capability	50 multiple kA (test pulse 8/20 μs)
Residual pulse energy	0.03 μJ typically (test pulse 4 kV 1.2/50 μs / 2 kA 8/20 μs) main path - protected side
Gas tube	No DC / shorted QW or LC

**COAXIAL SURGE PROTECTOR DEVICE, Quarter-wave stub technology with integrated high-pass filter**

3407.17.0022

Mechanical data	
Weight	580 g
Mating cycles	500

Environmental data	
Operation temperature	-40 °C ... 85°C
Storage temperature	-40 °C ... 85°C
Ingress protection (IP Rating)	IP66

Comment
SPD acc. EN 61643-21 category D1, high energy test 25 kA, 10/350 us Mounting set 9075.99.0040 for bulkhead mounting separately included

Ordering Information Table	
Item number	Item description
22652605	3407.17.0022

HUBER+SUHNER is certified by ISO 9001, ISO 14001, ISO 45001, IATF 16949, AS/EN 9100 and ISO/TS 22163-IRIS. Waiver: Facts and figures herein are for information only and do not represent any warranty of any kind.  
DOCUMENT PIM-P1965 / Date of publication: 16.11.2023 / uncontrolled copy